

ANALYTICAL REPORT

Job Number: 420-198822-1

SDG Number: Wallkill CSD Wallkill High School

Job Description: Ulster BOCES

For:
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Attention: Christy Fischer



Designee for
Meredith W Ruthven
Customer Service Manager
mruthven@envirotestlaboratories.com
07/24/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-198822-1
SDG Number: Wallkill CSD Wallkill High School

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Ulster BOCES

Job Number: 420-198822-1
SDG Number: Walkkill CSD Walkkill High School

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-198822-1
SDG Number: Wallkill CSD Wallkill High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-198822-1	Bottle Fill Outside Cafeteria	Drinking Water	05/28/2021 0531	06/01/2021 1138
420-198822-2	Kitchen Handwash Sink	Drinking Water	05/28/2021 0533	06/01/2021 1138
420-198822-3	Kitchen Pot Filler	Drinking Water	05/28/2021 0534	06/01/2021 1138
420-198822-4	Kitchen Island Sink	Drinking Water	05/28/2021 0535	06/01/2021 1138
420-198822-5	Kitchen Corner Sink by Pot Filler	Drinking Water	05/28/2021 0535	06/01/2021 1138
420-198822-6	Kitchen Bathroom Sink	Drinking Water	05/28/2021 0536	06/01/2021 1138
420-198822-7	Faculty Dining Room Sink	Drinking Water	05/28/2021 0536	06/01/2021 1138
420-198822-8	Girls PE Office Bath Sink	Drinking Water	05/28/2021 0538	06/01/2021 1138
420-198822-9	Womens Auditorium Bath Sink 1	Drinking Water	05/28/2021 0539	06/01/2021 1138
420-198822-10	Mens PE Office Bath Sink	Drinking Water	05/28/2021 0542	06/01/2021 1138
420-198822-11	124 Music Room Office Sink	Drinking Water	05/28/2021 0543	06/01/2021 1138
420-198822-12	T109 Sink	Drinking Water	05/28/2021 0545	06/01/2021 1138
420-198822-13	T106 Sink	Drinking Water	05/28/2021 0545	06/01/2021 1138
420-198822-14	Main Office Sink	Drinking Water	05/28/2021 0548	06/01/2021 1138
420-198822-15	Main Office Bath Sink	Drinking Water	05/28/2021 0548	06/01/2021 1138
420-198822-16	Librarians Office Sink	Drinking Water	05/28/2021 0550	06/01/2021 1138
420-198822-17	Social Worker's Office Sink	Drinking Water	05/28/2021 0551	06/01/2021 1138
420-198822-18	115 Sink	Drinking Water	05/28/2021 0552	06/01/2021 1138
420-198822-19	116B Sink	Drinking Water	05/28/2021 0554	06/01/2021 1138
420-198822-20	116A Sink 1	Drinking Water	05/28/2021 0554	06/01/2021 1138
420-198822-21	116A Sink 2	Drinking Water	05/28/2021 0555	06/01/2021 1138
420-198822-22	116A Sink 3	Drinking Water	05/28/2021 0555	06/01/2021 1138
420-198822-23	205 Spanish Office Sink	Drinking Water	05/28/2021 0559	06/01/2021 1138
420-198822-24	Left Staff Bath Outside 208 Sink 1	Drinking Water	05/28/2021 0600	06/01/2021 1138
420-198822-25	Left Staff Bath Outside 208 Sink 2	Drinking Water	05/28/2021 0600	06/01/2021 1138
420-198822-26	Right Staff Bath Sink Outside 208	Drinking Water	05/28/2021 0601	06/01/2021 1138
420-198822-27	Bottle Fill Outside Science Office by 216	Drinking Water	05/28/2021 0602	06/01/2021 1138
420-198822-28	Science Office Sinkby 220	Drinking Water	05/28/2021 0603	06/01/2021 1138
420-198822-29	219 Science Office Sink	Drinking Water	05/28/2021 0605	06/01/2021 1138
420-198822-30	Bottle Fill by 213	Drinking Water	05/28/2021 0606	06/01/2021 1138
420-198822-31	Girls Locker Room Bath Sink 1	Drinking Water	05/28/2021 0614	06/01/2021 1138
420-198822-32	Girls Locker Room Bath Sink 2	Drinking Water	05/28/2021 0614	06/01/2021 1138
420-198822-33	Boys Locker Room Water Cooler	Drinking Water	05/28/2021 0615	06/01/2021 1138
420-198822-34	Team Room Coaches Office Bath Sink	Drinking Water	05/28/2021 0613	06/01/2021 1138
420-198822-35	Boys Locker Room Coaches Office Bath Sink	Drinking Water	05/28/2021 0617	06/01/2021 1138
420-198822-36	Girls Locker Room Water Cooler	Drinking Water	05/28/2021 0620	06/01/2021 1138

SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-198822-1
SDG Number: Wallkill CSD Wallkill High School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-198822-37	Outside Women's Bath Sink	Drinking Water	05/28/2021 0619	06/01/2021 1138

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Bottle Fill Outside Cafeteria
Lab Sample ID: 420-198822-1

Date Sampled: 05/28/2021 0531
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0221	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Kitchen Handwash Sink
Lab Sample ID: 420-198822-2

Date Sampled: 05/28/2021 0533
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0223	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	2.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Kitchen Pot Filler
Lab Sample ID: 420-198822-3

Date Sampled: 05/28/2021 0534
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0228	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	7.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Kitchen Island Sink
Lab Sample ID: 420-198822-4

Date Sampled: 05/28/2021 0535
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0230	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.6	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Kitchen Corner Sink by Pot Filler
Lab Sample ID: 420-198822-5

Date Sampled: 05/28/2021 0535
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0236	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	40 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Kitchen Bathroom Sink
Lab Sample ID: 420-198822-6

Date Sampled: 05/28/2021 0536
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0239	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	4.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Faculty Dining Room Sink
Lab Sample ID: 420-198822-7

Date Sampled: 05/28/2021 0536
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0241	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	5.1	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Girls PE Office Bath Sink
Lab Sample ID: 420-198822-8

Date Sampled: 05/28/2021 0538
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0243	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Womens Auditorium Bath Sink 1
Lab Sample ID: 420-198822-9

Date Sampled: 05/28/2021 0539
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0245	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Mens PE Office Bath Sink
Lab Sample ID: 420-198822-10

Date Sampled: 05/28/2021 0542
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0247	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	7.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: 124 Music Room Office Sink
Lab Sample ID: 420-198822-11

Date Sampled: 05/28/2021 0543
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0249	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	17	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: T109 Sink
Lab Sample ID: 420-198822-12

Date Sampled: 05/28/2021 0545
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0252	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	7.4	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: T106 Sink
Lab Sample ID: 420-198822-13

Date Sampled: 05/28/2021 0545
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0254	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	4.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Main Office Sink
Lab Sample ID: 420-198822-14

Date Sampled: 05/28/2021 0548
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0307	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	5.3	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Main Office Bath Sink
Lab Sample ID: 420-198822-15

Date Sampled: 05/28/2021 0548
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0309	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Librarians Office Sink
Lab Sample ID: 420-198822-16

Date Sampled: 05/28/2021 0550
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0311	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.5	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Social Worker's Office Sink
Lab Sample ID: 420-198822-17

Date Sampled: 05/28/2021 0551
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0313	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	28	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: 115 Sink
Lab Sample ID: 420-198822-18

Date Sampled: 05/28/2021 0552
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0316	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	12	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: 116B Sink
Lab Sample ID: 420-198822-19

Date Sampled: 05/28/2021 0554
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0318	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	31	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: 116A Sink 1
Lab Sample ID: 420-198822-20

Date Sampled: 05/28/2021 0554
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0320	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	21	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: 116A Sink 2
Lab Sample ID: 420-198822-21

Date Sampled: 05/28/2021 0555
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0322	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	5.7	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: 116A Sink 3
Lab Sample ID: 420-198822-22

Date Sampled: 05/28/2021 0555
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0329	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	5.9	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: 205 Spanish Office Sink
Lab Sample ID: 420-198822-23

Date Sampled: 05/28/2021 0559
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0333	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	7.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Left Staff Bath Outside 208 Sink 1
Lab Sample ID: 420-198822-24

Date Sampled: 05/28/2021 0600
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0335	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	13	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Left Staff Bath Outside 208 Sink 2
Lab Sample ID: 420-198822-25

Date Sampled: 05/28/2021 0600
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0337	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	11	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Right Staff Bath Sink Outside 208
Lab Sample ID: 420-198822-26

Date Sampled: 05/28/2021 0601
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0340	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.8	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Bottle Fill Outside Science Office by 216
Lab Sample ID: 420-198822-27

Date Sampled: 05/28/2021 0602
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0342	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Science Office Sinkby 220
Lab Sample ID: 420-198822-28

Date Sampled: 05/28/2021 0603
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0344	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	39 g	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: 219 Science Office Sink
Lab Sample ID: 420-198822-29

Date Sampled: 05/28/2021 0605
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0346	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	75	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Bottle Fill by 213
Lab Sample ID: 420-198822-30

Date Sampled: 05/28/2021 0606
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0348	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Girls Locker Room Bath Sink 1
Lab Sample ID: 420-198822-31

Date Sampled: 05/28/2021 0614
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0355	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	25	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Girls Locker Room Bath Sink 2
Lab Sample ID: 420-198822-32

Date Sampled: 05/28/2021 0614
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0357	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	2.0	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Boys Locker Room Water Cooler
Lab Sample ID: 420-198822-33

Date Sampled: 05/28/2021 0615
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0359	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Team Room Coaches Office Bath Sink
Lab Sample ID: 420-198822-34

Date Sampled: 05/28/2021 0613
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0408	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	51	g	ug/L	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Wallkill CSD Wallkill High School

Client Sample ID: Boys Locker Room Coaches Office Bath Sink
Lab Sample ID: 420-198822-35

Date Sampled: 05/28/2021 0617
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0410	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Girls Locker Room Water Cooler
Lab Sample ID: 420-198822-36

Date Sampled: 05/28/2021 0620
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0412	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer
Ulster BOCES
175 Route 32 North
New Paltz, NY 12561

Job Number: 420-198822-1
Sdg Number: Walkill CSD Walkill High School

Client Sample ID: Outside Women's Bath Sink
Lab Sample ID: 420-198822-37

Date Sampled: 05/28/2021 0619
Date Received: 06/01/2021 1138
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0414	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	14	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:
Sdg Number: Walkill CSD Walkill High School

Lab Section	Qualifier	Description
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Wallkill CSD Wallkill High School

The following analytes are Not Part of the ELAP scope of accreditation:

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation:

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary




Client: Ulster BOCES

Job Number:

Sdg Number: Walkill CSD Walkill High School

<u>Abbreviation</u>	<u>These commonly used abbreviations may or may not be present in this report.</u>
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

Chain of Custody Record

Client Information Client Contact: C Fischer Phone: 845 255-1400 X1361		Sampler: C Fischer Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 198822						
Company: Walkill CSD C/O Ulster BOCES				Analysis Requested				Page: Page 1 of 3				
Address: 1500 Route 208		Due Date Requested:		<div style="border: 1px solid black; padding: 5px; text-align: center;">  420-198822-B-1 Bottle Fill Outside Cafeteria Date Sampled: 5/28/2021 420-1704032 </div>				Preservation Codes: A - HCL L - EDA B - NaOH M - Sodium Sulfite C - Zn Acetate N - None D - Nitric Acid O - MCAA E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other:				
City: Walkill		TAT Requested (days):										
State, Zip: NY, 12589		PO #:										
Phone: 845-2551400 X1361		PWS #:										
Email: cfischer@ulsterbores.org		Project #:										
Project Name: Walkill CSD		Additional Contacts: Please email results to: cfischer@ulsterbores.org and srossi@walkillcsd.k12.ny.us										
Site: Walkill High School												
Sample Identification	Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oi)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Pres	Lead (DW 200)	Total Number of Containers	Upon Receipt Preservation verified: Y / N	Special Instructions/Note:
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle												
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other												
Preservation Added Upon Receipt: Manufacturer/Lot #:		Date:		Time:		Sample # (s):						
Relinquished by: 		Date/Time: 6/1/21 1138		Company: ulsterbores		Received by: 		Date/Time: 6/01/21 1138		Company: ETZ		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:		
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:		Company:		
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Cooler Temperature(s) °C/ IR GUN #: 22.0 C		07/24/2021				

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: C Fischer		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 198822	
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterbores.org and srossi@walkkillcsd.k12.ny.us					
Company: Walkill CSD C/O Ulster BOCES				Analysis Requested				Page: Page 2 of 3	
Address: 1500 Route 208		Due Date Requested:		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8)				Total Number of Containers	
City: Walkill		TAT Requested (days):							
State, Zip: NY, 12589		PO #:							
Phone: 845-2551400 X1361		PWS #:							
Email: cfischer@ulsterbores.org		Project #:							
Project Name: Walkill CSD		Additional Contacts: Please email results to: cfischer@ulsterbores.org and srossi@walkillcsd.k12.ny.us							
Site: Walkill High School									
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)				
				Preservation Code:					
Librarian's Office Sink		5/28/21	550	G	DW				
Social Worker's Office Sink		5/28/21	551	G	DW				
115 Sink		5/28/21	552	G	DW				
116B Sink		5/28/21	554	G	DW				
116A Sink 1		5/28/21	554	G	DW				
116A Sink 2		5/28/21	555	G	DW				
116A Sink 3		5/28/21	555	G	DW				
205 Spanish Office Sink		5/28/21	559	G	DW				
Left Staff Bath Outside 208 Sink 1		5/28/21	600	G	DW				
Left Staff Bath Outside 208 Sink 2		5/28/21	600	G	DW				
Right Staff Bath Sink Outside 208		5/28/21	601	G	DW				
Bottle Fill Outside Science Office by 216		5/28/21	602	G	DW				
Science Office Sink by 220		5/28/21	603	G	DW				
219 Science Office Sink		5/28/21	605	G	DW				
Bottle Fill by 213		5/28/21	606	G	DW				
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle						P		Container Type	
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other						2		Container Size	
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):			
Relinquished by: <i>[Signature]</i>		Date/Time: 6/1/21 1138		Company: <i>Walkill</i>		Received by: <i>GA</i>		Date/Time: 6/01/21 1138	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:	
ICE Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Custody Seal No.:		Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Center Temperature(s) °C / IR GUN #: 22.0 C		07/24/2021	

EnviroTest Laboratories, LLC

315 Fullerton Avenue
 Newburgh, NY 12550
 Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record



Client Information		Sampler: C Fischer	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #: 198822						
Client Contact: C Fischer		Phone: 845 255-1400 X1361	E-Mail: cfischer@ulsterboces.org and srossi@walkkillcsd.k12.ny.us		Page: Page 3 of 3						
Company: Walkill CSD C/O Ulster BOCES		Analysis Requested			Preservation Codes:						
Address: 1500 Route 208	Due Date Requested:				Total Number of Containers	A - HCL	L- EDA				
City: Walkill	TAT Requested (days):	B - NaOH	M - Sodium Sulfit								
State, Zip: NY, 12589	PO #:	C - Zn Acetate	N - None								
Phone: 845-2551400 X1361	PWS #:	D - Nitric Acid	O - MCAA								
Email: cfischer@ulsterboces.org	Project #:	E - H2SO4	P - Other (specify)								
Project Name: Walkill CSD	Additional Contacts: Please email results to: cfischer@ulsterboces.org and srossi@walkkillcsd.k12.ny.us	F - MeOH	G - NH4CL								
Site: Walkill High School		H - Ascorbic Acid	I - Ice								
		J - DI Water	K - Sodium Thiosulfate	Other:							
					Upon Receipt Preservation verified: Y / N						
Sample Identification	Client ID (Lab ID)	Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead (DW 200.8)	Special Instructions/Note:	
Girls Locker Room Bath Sink 1		5/28/21	614	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Girls Locker Room Bath Sink 2		5/28/21	614	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Boys Locker Room Water Cooler		5/28/21	615	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Team Room Coaches Office Bath Sink		5/28/21	613	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Boys Locker Room Coaches Office Bath Sink		5/28/21	617	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Girls Locker Room Water Cooler		5/28/21	620	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Outside Women's Bath Sink		5/28/21	619	G	DW	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	X		
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle										P	Container Type
Size Code: 1=1 Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other										2	Container Size
Preservation Added Upon Receipt:		Date:	Time:		Sample # (s):						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
<i>[Signature]</i>	6/1/21 1138	ulsterboces	<i>[Signature]</i>	6/1/21 1138	ETL						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
Relinquished by:	Date/Time:	Company:	Received by:	Date/Time:	Company:						
ICE Present: Δ Yes Δ No	Custody Seal No.:	Custody Seals Intact: Yes Δ No	Page 18 of 19	Cooler Temperature(s) °C/IR GUN #:	22.0 °C						

07/24/2021

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-198822-1
SDG Number: Wallkill CSD Wallkill High School

Login Number: 198822

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	False	
Cooler Temperature is recorded.	True	22.0 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	False	
If false, was sample received on ice within 6 hours of collection.	False	
Based on above criteria cooler temperature is acceptable.	True	Method does not require cooling
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	