

## ANALYTICAL REPORT

Job Number: 420-198608-1  
SDG Number: Wallkill Middle School  
Job Description: Ulster BOCES

For:  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Attention: Christy Fischer



---

Designee for  
Meredith W Ruthven  
Customer Service Manager  
mruthven@envirotestlaboratories.com  
07/24/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at [Envirotestlabs/terms.com](http://Envirotestlabs/terms.com). As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOH PH-0554

## METHOD SUMMARY

Client: Ulster BOCES

Job Number: 420-198608-1  
SDG Number: Walkill Middle School

<b>Description</b>	<b>Lab Location</b>	<b>Method</b>	<b>Preparation Method</b>
<b>Matrix: Water</b>			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

### Lab References:

EnvTest = EnviroTest

### Method References:

EPA = US Environmental Protection Agency

**METHOD / ANALYST SUMMARY**

Client: Ulster BOCES

Job Number: 420-198608-1  
SDG Number: Walkill Middle School

<b>Method</b>	<b>Analyst</b>	<b>Analyst ID</b>
EPA 200.8 Rev.5.4	Luis, Carlos	CL

## SAMPLE SUMMARY

Client: Ulster BOCES

Job Number: 420-198608-1  
SDG Number: Walkill Middle School

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-198608-1	Kitchen Food Prep Sink	Drinking Water	05/28/2021 0643	06/01/2021 1138
420-198608-2	Kitchen Bath Sink	Drinking Water	05/28/2021 0643	06/01/2021 1138
420-198608-3	Kitchen Handwash Sink	Drinking Water	05/28/2021 0644	06/01/2021 1138
420-198608-4	Ice Machine	Drinking Water	05/28/2021 0645	06/01/2021 1138
420-198608-5	Cafeteria Bottle Fill	Drinking Water	05/28/2021 0647	06/01/2021 1138
420-198608-6	Bottle Fill Outside 100	Drinking Water	05/28/2021 0647	06/01/2021 1138
420-198608-7	Office Bath Sink	Drinking Water	05/28/2021 0648	06/01/2021 1138
420-198608-8	Office Kitchen Sink	Drinking Water	05/28/2021 0649	06/01/2021 1138
420-198608-9	104 Sink 1	Drinking Water	05/28/2021 0651	06/01/2021 1138
420-198608-10	104 Sink 2	Drinking Water	05/28/2021 0651	06/01/2021 1138
420-198608-11	104 Sink 3	Drinking Water	05/28/2021 0651	06/01/2021 1138
420-198608-12	104 Sink 4	Drinking Water	05/28/2021 0651	06/01/2021 1138
420-198608-13	Bottle Fill Outside 105	Drinking Water	05/28/2021 0652	06/01/2021 1138
420-198608-14	Girls Locker Room Sink 1	Drinking Water	05/28/2021 0654	06/01/2021 1138
420-198608-15	Girls Locker Room Sink 2	Drinking Water	05/28/2021 0654	06/01/2021 1138
420-198608-16	Boys Locker Room Sink 1	Drinking Water	05/28/2021 0655	06/01/2021 1138
420-198608-17	Boys Locker Room Sink 2	Drinking Water	05/28/2021 0655	06/01/2021 1138
420-198608-18	Women's Bath Outside Faculty Room Sink	Drinking Water	05/28/2021 0658	06/01/2021 1138
420-198608-19	Faculty Room Sink	Drinking Water	05/28/2021 0658	06/01/2021 1138
420-198608-20	Bottle Fill Outside Faculty Room	Drinking Water	05/28/2021 0659	06/01/2021 1138
420-198608-21	Men's Bath Sink Outside Faculty Room	Drinking Water	05/28/2021 0659	06/01/2021 1138
420-198608-22	Nurse's Office Sink	Drinking Water	05/28/2021 0700	06/01/2021 1138
420-198608-23	Bath Outside Nurse's Office	Drinking Water	05/28/2021 0701	06/01/2021 1138
420-198608-24	Bottle Fill Outside 214	Drinking Water	05/28/2021 0701	06/01/2021 1138
420-198608-25	Bottle Fill Outside 306	Drinking Water	05/28/2021 0704	06/01/2021 1138
420-198608-26	309 Open Area Sink	Drinking Water	05/28/2021 0704	06/01/2021 1138

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Kitchen Food Prep Sink  
**Lab Sample ID:** 420-198608-1

Date Sampled: 05/28/2021 0643  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0056	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.7	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Kitchen Bath Sink  
**Lab Sample ID:** 420-198608-2

Date Sampled: 05/28/2021 0643  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0105	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	6.9	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Kitchen Handwash Sink  
**Lab Sample ID:** 420-198608-3

Date Sampled: 05/28/2021 0644  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0107	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	6.4	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkill Middle School

**Client Sample ID:** Ice Machine  
**Lab Sample ID:** 420-198608-4

Date Sampled: 05/28/2021 0645  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 07/22/2021 0109	
Prep Method: 200.7/200.8				Date Prepared: 07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0



Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Cafeteria Bottle Fill  
**Lab Sample ID:** 420-198608-5

Date Sampled: 05/28/2021 0647  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0111	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Bottle Fill Outside 100  
**Lab Sample ID:** 420-198608-6

Date Sampled: 05/28/2021 0647  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				07/22/2021 0118	
Prep Method: 200.7/200.8				07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Office Bath Sink  
**Lab Sample ID:** 420-198608-7

Date Sampled: 05/28/2021 0648  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0120	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.6	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Office Kitchen Sink  
**Lab Sample ID:** 420-198608-8

Date Sampled: 05/28/2021 0649  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0122	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.3	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** 104 Sink 1  
**Lab Sample ID:** 420-198608-9

Date Sampled: 05/28/2021 0651  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0124	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	3.7	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** 104 Sink 2  
**Lab Sample ID:** 420-198608-10

Date Sampled: 05/28/2021 0651  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0127	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	4.7	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** 104 Sink 3  
**Lab Sample ID:** 420-198608-11

Date Sampled: 05/28/2021 0651  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0131	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	23	g	ug/L	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** 104 Sink 4  
**Lab Sample ID:** 420-198608-12

Date Sampled: 05/28/2021 0651  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0133	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	10	ug/L	1.0	1.0	1.0



Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Bottle Fill Outside 105  
**Lab Sample ID:** 420-198608-13

Date Sampled: 05/28/2021 0652  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 07/22/2021 0135	
Prep Method: 200.7/200.8				Date Prepared: 07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Girls Locker Room Sink 1  
**Lab Sample ID:** 420-198608-14

Date Sampled: 05/28/2021 0654  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0138	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	4.1	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Girls Locker Room Sink 2  
**Lab Sample ID:** 420-198608-15

Date Sampled: 05/28/2021 0654  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0144	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	2.3	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Boys Locker Room Sink 1  
**Lab Sample ID:** 420-198608-16

Date Sampled: 05/28/2021 0655  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0146	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	4.7	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Boys Locker Room Sink 2  
**Lab Sample ID:** 420-198608-17

Date Sampled: 05/28/2021 0655  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0148	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	2.6	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Women's Bath Outside Faculty Room Sink  
**Lab Sample ID:** 420-198608-18

Date Sampled: 05/28/2021 0658  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0151	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.2	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Faculty Room Sink  
**Lab Sample ID:** 420-198608-19

Date Sampled: 05/28/2021 0658  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0153	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	2.9	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Bottle Fill Outside Faculty Room  
**Lab Sample ID:** 420-198608-20

Date Sampled: 05/28/2021 0659  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0201	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0



Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Men's Bath Sink Outside Faculty Room  
**Lab Sample ID:** 420-198608-21

Date Sampled: 05/28/2021 0659  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0204	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.8	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Nurse's Office Sink  
**Lab Sample ID:** 420-198608-22

Date Sampled: 05/28/2021 0700  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0210	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Bath Outside Nurse's Office  
**Lab Sample ID:** 420-198608-23

Date Sampled: 05/28/2021 0701  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0212	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	7.8	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Bottle Fill Outside 214  
**Lab Sample ID:** 420-198608-24

Date Sampled: 05/28/2021 0701  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 07/22/2021 0215	
Prep Method: 200.7/200.8				Date Prepared: 07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** Bottle Fill Outside 306  
**Lab Sample ID:** 420-198608-25

Date Sampled: 05/28/2021 0704  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed: 07/22/2021 0217	
Prep Method: 200.7/200.8				Date Prepared: 07/19/2021 0900	
Pb	1.0 U	ug/L	1.0	1.0	1.0

Christy Fischer  
Ulster BOCES  
175 Route 32 North  
New Paltz, NY 12561

Job Number: 420-198608-1  
Sdg Number: Walkkill Middle School

**Client Sample ID:** 309 Open Area Sink  
**Lab Sample ID:** 420-198608-26

Date Sampled: 05/28/2021 0704  
Date Received: 06/01/2021 1138  
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	07/22/2021 0219	
Prep Method: 200.7/200.8			Date Prepared:	07/19/2021 0900	
Pb	8.2	ug/L	1.0	1.0	1.0

## DATA REPORTING QUALIFIERS

Client: Ulster BOCES

Job Number:  
Sdg Number: Walkill Middle School

<b>Lab Section</b>	<b>Qualifier</b>	<b>Description</b>
Metals		
	g	Result fails applicable NYS drinking water standards
	U	The analyte was analyzed for but not detected at or above the lowest stated limit.

## Certification Information

Client: Ulster BOCES

Job Number:

Sdg Number: Walkkill Middle School

---

### **The following analytes are Not Part of the ELAP scope of accreditation:**

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

### **The following analytes are Not Part of ELAP Potable Water scope of accreditation:**

Ammonia (SM 4500NH3G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Setttable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

### **The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation:**

Ammonia (SM 4500NH3G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

### **The following analytes are Not Part of ELAP Non Potable Water scope of accreditation:**

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).



## Definitions and Glossary

Client: Ulster BOCES

Job Number:

Sdg Number: Walkill Middle School

---

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points.

Chain of Custody Record

<b>Client Information</b>		Sampler: C Fischer		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 98609 102																																																																									
Client Contact: C Fischer		Phone: 845 255-1400 X1361		E-Mail: cfischer@ulsterbores.org and srossi@walkillcstd.k12.ny.us																																																																													
Company: Walkill CSD C/O Ulster BOCES					<b>Analysis Requested</b>																																																																												
Address: 1500 Route 208		Due Date Requested:		<table border="1"> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> <tr><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>																																																																												Page: Page 1 of 2	
City: Walkill		TAT Requested (days):		Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate		L- EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)		Other:																																																																									
State, Zip: NY, 12589		PO #:		Total Number of containers				Upon Receipt Preservation verified: Y / N																																																																									
Phone: 845-2551400 X1361		PWS #:																																																																															
Email: cfischer@ulsterbores.org		Project #:																																																																															
Project Name: Walkill CSD		Additional Contacts: Please email results to: cfischer@ulsterbores.org and srossi@walkillcstd.k12.ny.us																																																																															
Site: Walkill Middle School																																																																																	
<b>Sample Identification</b> Client ID (Lab ID)		Sample Date		Sample Time		Sample Type (C=Comp, G=grab)		Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)																																																																									
								Field Filtered Sample (Yes or No)																																																																									
								Perform MS/MSD (Yes or No)																																																																									
								Chlorine Present (Yes or No)																																																																									
								Lead (DW 200.8)																																																																									
								Preservation Code:																																																																									
Kitchen Food Prep Sink		5/28/21		643		G DW		X																																																																									
Kitchen Bath Sink		5/28/21		643		G DW		X																																																																									
Kitchen Handwash Sink		5/28/21		644		G DW		X																																																																									
Ice Machine		5/28/21		645		G DW		X																																																																									
Cafeteria Bottle Fill		5/28/21		647		G DW		X																																																																									
Bottle Fill Outside 100		5/28/21		647		G DW		X																																																																									
Office Bath Sink		5/28/21		648		G DW		X																																																																									
Office Kitchen Sink		5/28/21		649		G DW		X																																																																									
104 Sink 1		5/28/21		651		G DW		X																																																																									
104 Sink 2		5/28/21		651		G DW		X																																																																									
104 Sink 3		5/28/21		651		G DW		X																																																																									
104 Sink 4		5/28/21		651		G DW		X																																																																									
Bottle Fill Outside 105		5/28/21		652		G DW		X																																																																									
Girls Locker Room Sink 1		5/28/21		654		G DW		X																																																																									
Girls Locker Room Sink 2		5/28/21		654		G DW		X																																																																									
								Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle																																																																									
								Container Type																																																																									
								Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other																																																																									
								Container Size																																																																									
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):																																																																											
Manufacturer/Lot #:																																																																																	
Relinquished by: <i>[Signature]</i>		Date/Time: 6/1/21 1135		Company: <i>[Signature]</i>		Received by: <i>[Signature]</i>		Date/Time: 6/1/21 1138																																																																									
								Company: ETL																																																																									
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:																																																																									
Relinquished by:		Date/Time:		Company:		Received by:		Date/Time:																																																																									
ICE Present: Δ Yes Δ No		Custody Seal No.:		Custody Seals Intact: Yes Δ No		Cooler Temperature(s) °C/ IR GUN #: 22.0°C		07/24/2021																																																																									



420-198608-B-1  
Kitchen Food Prep Sink  
Date Sampled: 5/28/2021 420-1702067

Chain of Custody Record

<b>Client Information</b>		Sampler: C Fischer	Lab PM:	Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):	JOB #:  198608 242	
Client Contact: C Fischer		Phone: 845 255-1400 X1361	E-Mail: cfischer@ulsterbores.org and srossi@walkkillcsd.k12.ny.us			
Company: Walkill CSD C/O Ulster BOCES		Analysis Requested			Page: Page 2 of 4	
Address: 1500 Route 208	Due Date Requested:		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead (DW 200.8)	Total Number of Containers	Preservation Codes: A - HCL B - NaOH C - Zn Acetate D - Nitric Acid E - H2SO4 F - MeOH G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)  Other:  Upon Receipt Preservation verified: Y / N	
City: Walkill	TAT Requested (days):					
State, Zip: NY, 12589	PO #:					
Phone: 845-2551400 X1361	PWS #:					
Email: cfischer@ulsterbores.org	Project #:					
Project Name: Walkill CSD	Additional Contacts: Please email results to: cfischer@ulsterbores.org and srossi@walkkillcsd.k12.ny.us					
Site: Walkill Middle School						
Sample Identification Client ID (Lab ID)	Sample Date	Sample Time				Sample Type (C=Comp, G=grab)
Boys Locker Room Sink 1	5/28/21	655	G	DW	X	
Boys Locker Room Sink 2	5/28/21	655	G	DW	X	
Women's Bath Outside Faculty Room Sink	5/28/21	658	G	DW	X	
Faculty Room Sink	5/28/21	658	G	DW	X	
Bottle Fill Outside Faculty Room	5/28/21	659	G	DW	X	
Men's Bath Sink Outside Faculty Room	5/28/21	659	G	DW	X	
Nurse's Office Sink	5/28/21	700	G	DW	X	
Bath Outside Nurse's Office	5/28/21	701	G	DW	X	
Bottle Fill Outside 214	5/28/21	701	G	DW	X	
Bottle Fill Outside 306	5/28/21	704	G	DW	X	
309 Open Area Sink	5/28/21	704	G	DW	X	
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle					P	Container Type
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other					2	Container Size
Preservation Added Upon Receipt:		Date:	Time:	Sample # (s):		
Manufacturer/Lot #:		Date/Time: 6/1/21 1138		Company: ulsterbores	Received by: [Signature]	Date/Time: 6/1/21 1138 Company: ETL
Relinquished by: [Signature]		Date/Time:		Company:	Received by:	Date/Time: Company:
Relinquished by:		Date/Time:		Company:	Received by:	Date/Time: Company:
Relinquished by:		Date/Time:		Company:	Received by:	Date/Time: Company:
ICE Present: Δ Yes Δ No	Custody Seal No.:	Custody Seals Intact: Yes Δ No	Page 35 of 36	Cooler Temperature(s) °C/ IR GUN #: 22.0°C	07/24/2021	

## LOGIN SAMPLE RECEIPT CHECK LIST

Client: Ulster BOCES

Job Number: 420-198608-1  
SDG Number: Walkill Middle School

**Login Number: 198608**

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	22.0C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	True	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	